DOORS & WINDOWS

Double-Glazed Cleanroom Vision Window

双层玻璃视窗

A commissioned report covering construction, fragmentation and watertightness of a double-glazed vision window.

Document number	CBT10502181961
Issue date	2025-10-22
Standards	GB 15763.2-2005; GB/T 7106-2019; GB/T 8478-2020. Assessment: enterprise technical requirements.
Applicant / holder	浙江艾绿净化科技有限公司
Issuing organization	广东省宝通质量检测有限公司

Recorded Results

Tested specimen	600 x 2400 mm; one window set
Appearance, assembly and construction	Pass
Fragmentation	46 and 48 fragments in the indicated 50 x 50 mm assessment area
Watertightness	400 Pa for 15 min; no leakage
Overall conclusion	Tested items met the stated requirements; pass

Sample and Test Conditions

Client-submitted specimen received 7 October 2025. Testing took place 10-22 October 2025.

The inspected report does not state glass thickness. The complete Chinese source includes the original criteria and result table.

Scope of This Document

The listed tests do not establish an acoustic, thermal, fire-resistance or glazing-seal-life rating.

Read the complete Chinese document for the original tables, drawings, seals and stated conditions.